

TEST RECORD

Pressure Test & Disinfection — WM-12 to WM-15

Project	Sample Project	Work type	Pressure Test & Disinfection
Section tested	WM-12 to WM-15	From GPS	38.503420, -97.608115
To GPS	38.503402, -97.603288	Date completed	10/05/2026

Result

Bac-T sample passed

Yes

Test pressure	150 PSI	Test held	120 min
Pressure drop	0 PSI	Chlorine residual	1.2 ppm

Notes

Example sheet rendered from sample data. The result prints exactly as the crew recorded it; the sheet never works one out from the readings.